

TABLE II
VENTILATION RATE TABLE

NOTE: Does not apply to those Facilities exempted with an "Asterisk" in Table I

ROOM OR FUNCTION	RELATIVE PRESSURE	MINIMUM TOTAL ROOM VOLUMES PER HOUR	MINIMUM OUTDOOR AIR ROOM VOLUMES PER HOUR	ALL AIR EXHAUSTED DIRECTLY TO OUTDOORS
Resident Room	0	2	1	No
Corridor	0	2	1	No
Special Purpose	0	2	1	No
Toilets and Baths	-	10	-	Yes
Dining and Recreation	0	4	2	No
Barber and Beauty	0	2	1	No
Physical Therapy	-	4	2	No
Hydro Therapy	-	4	2	No
Clean Utility	+	10	2	No
Soiled Utility room	-	10	2	Yes
Clean Linen	+	2	1	No
Soiled Linen	-	10	-	Yes
Janitor's Closet	-	10	-	Yes
Nourishment Room	0	4	2	No
Drug Room	+	4	2	No
Kitchen	0	20	7	No
Trash Room	-	10	-	Yes
Oxygen Tank Room	-	8	-	Yes
Laundry	0	10	3	Yes
Locker Room	0	4	1	Yes
Dishwashing	-	6	-	Yes
Maintenance	-	2	1	Yes

Administrative areas shall be designed for comfort conditions and shall be provided with no less than five cubic feet per minute per person of outdoor air.